



1
ca. 804 qm

2
ca. 742 qm

3
ca. 767 qm

5
ca. 663 qm

6
ca. 698 qm

4
ca. 623 qm

1282/4

1282/5

1281/2

1281/1

1281b

1278

1278e

1278

1278f

Steinstraße

Regelprofil

Anlage 1 zur Begründung
Erschließungsplan
Datum: 27.01.2023 M 1:250

MW3
KD=273,51
RS=271,31
t=2,20m

MW2
KD=273,32
RS=271,12
t=2,20m

MW1
KD=273,14
RS=270,44
t=2,70m

321749
KD=274,14
RS=271,75
t=2,39m

KD=274,97
Uhy

DN 500 SB, 56,10m, 5,56%
100 St. 1927

L = 64,98m, I = 0,6% -->

DN 250 PP, 31,05m, 0,6% -->

DN 250 PP, 35,60m, 1,91% -->

Tiefbordstein
3,50
Tiefbordstein

15,80

5,00

4,70

R3,00

R2,00

R2,00

AS

AS

AS

3x AS

Uhy (Spülhydrant)

Trasse Kabel
d 75 PE-HD

Rundbordstein

Rundbordstein

SA3

SA2

SA1

1281a

24

22

23

21

